

HOW TO PREVENT LEGIONELLA DURING EXTENDED BUILDING SHUTDOWNS

Extended building closures can place water systems at risk for amplifying Legionella bacteria that can pose a risk to human health. Although the bacteria that causes Legionella occurs in natural water sources, outbreaks are generally caused by the amplified growth and aerosolization of the bacteria from man-made water systems.

What is Legionella?

Legionella (Legionnaires' disease) is a serious pneumonia associated with a high fever. Approximately 10% of those infected will die. It was discovered following the 1976 American Legion convention at The Bellevue-Stratford Hotel in Philadelphia, where 211 persons became ill, and 29 died.

Many buildings do not have formal water management plans, and sudden, and extended discontinued use of the water systems may increase the risk of stagnant water remaining in the plumbing for several weeks or months. Stagnant water from plumbing lines can be easily aerosolized and create a mist when discharged through shower heads, faucets, and garden fixtures. The fine mist can be inhaled, permitting the bacteria that causes Legionella to enter the lungs and cause infection.

There is also an increased risk for bacteria growth in water from cooling towers, fountains, humidifiers, etc. if not properly maintained during a shutdown. It is critical to reduce the opportunity for bacteria to amplify in stagnant water or water trapped in pipes to help prevent Legionella during a shutdown. There are simple measures that all property and business owners can take to reduce the risk.

Pre-Shutdown Activities

- Identify all water sources and fixtures.
- Drain and disinfect indoor water features and fountains.
- Drain water from all process equipment dishwashers, floor cleaners, tools, and medical equipment.
- Assign a team to inspect the building on at least a weekly basis.
- Pre-treat boilers and water cooling towers as necessary.

During the Shutdown

- Inspect the entire building for water leaks or broken fixtures.
- Run hot and cold water from each fixture (i.e., shower heads, sinks, hoses, spray hoses) for 5 to 7 minutes each week.
- Continue to inspect emergency eyewash and shower stations by running them every week.
- Inspect outdoor fixtures and other areas that can accumulate stagnant water.
- Maintain climate control systems.
- Maintain pool and spa equipment chemistry at normal levels.
- Flush all toilets weekly.
- Maintain water heaters at 140° F.

During Start-Up

- Inspect, clean, and disinfect all water features and fountains.
- Inspect, clean, and disinfect water cooling towers.
- Defrost, drain, sanitize, and replace the filters on commercial ice machines.
- Confirm proper chlorination of pools and spas.
- Inspect all equipment that has water tanks for bio-film, and disinfect as necessary.

Additional information on water management can be found [here](#).

https://www.cdc.gov/legionella/wmp/toolkit/index.html?CDC_AA_refVal=https%3A%2F%2Fwww.cdc.gov%2Flegionella%2Fwmp%2F toolkit%2Findex.html

Please note, this content is intended to provide guidance to building and business owners that are not required to have a formal Water Management Plan (WMP).

Please be advised that any and all information, comments, analysis, and/or recommendations set forth above relative to the possible impact of COVID-19 on potential insurance coverage or other policy implications are intended solely for informational purposes and should not be relied upon as legal or medical advice. As an insurance broker, we have no authority to make coverage decisions as that ability rests solely with the issuing carrier. Therefore, all claims should be submitted to the carrier for evaluation. The positions expressed herein are opinions only and are not to be construed as any form of guarantee or warranty. Finally, given the extremely dynamic and rapidly evolving COVID-19 situation, comments above do not take into account any applicable pending or future legislation introduced with the intent to override, alter or amend current policy language.